

# California DG Program

---



**CHP Turbine  
Technology and National  
Regulatory Forum  
San Diego, 2003**

Air Resources Board

California Environmental Protection Agency



# Today's Presentation

---

- **Background**
- **DG Certification Program**
- **DG Guidance**

# Today's Presentation

---

- **Background**
- **DG Certification Program**
- **DG Guidance**

# Background

---

- **California Air Quality Programs for Stationary Sources**
- **SB 1298 (2000)**

# Stationary Source Programs

---

- **Administered by Local Districts**
- **Permits Required for Most Sources of Air Pollution**

# What Does SB 1298 Require?

---

- Commencing January 2003, all DG technologies must be either certified by ARB or permitted by one of California's 35 Air Districts prior to use or operation



# **What Does SB 1298 Require? (Continued)**

---

- **Adopt DG Certification Program,  
Including Uniform Emission Standards**
- **Provide Guidance to the Districts for  
Permitting of Electrical  
Generation Technologies**

# Program Status

---

- **Certification Program Approved by Board**
  - **Program Effective October 2002**
- **Board Approved Guidance**

# Today's Presentation

---

- Background
- **DG Certification Program**
- DG Guidance

# Applicability

---

- **Applies to Manufacturers**
- **New Units Sold After January 1, 2003**
- **Examples of Affected Equipment**
  - **Microturbines (Less Than 300 kw)**
  - **Fuel Cells**

# **Applicability**

## **(Continued)**

---

- **Not Included**
  - **Emergency Standby**
  - **Portable**



**Microturbine**



**Fuel Cell**

# 2003 Emission Standards (lb/MW-hr)

---

	<u>NOx</u>	<u>VOC</u>	<u>CO</u>
<b>Without CHP</b>	<b>0.5</b>	<b>1.0</b>	<b>6.0</b>
<b>With CHP</b>	<b>0.7</b>	<b>1.0</b>	<b>6.0</b>

# 2007 Emission Standards (lb/MW-hr)

---

NOx

0.07


VOC

0.02


CO

0.1

# DG and Central Station Power Plant NOx Emissions



# Microturbine NOx Emissions Versus Power Load



# **Technical Review by July 2005**

---

- **Evaluate Testing Procedures**
- **Evaluate Emissions Durability**
- **Evaluate CHP Benefit**
- **Evaluate 2007 Standards**

# Certification Program Status

---

- **Certified Equipment**
  - **Fuel Cell**
  - **Microturbine**

# Today's Presentation

---

- Background
- DG Certification Program
- **DG Guidance**

# What Does the DG Guidance Address?

---

- **Electrical Generation < 50 MW**
- **Recommended BACT Levels**
- **Attainment of Central Station  
Power Plant Levels**



**Turbine with CHP**



**Internal Combustion Engine**



# Waste Gas Flare and Engine

# Recommended BACT Levels For Turbines (lb/MW-Hr)

---

<u>Size (MW)</u>	<u>Type</u>	<u>NOx</u>	<u>VOC</u>	<u>CO</u>
< 3	--	0.5	0.1	0.4
3-12	CC	0.12	0.04	0.2
	SC	0.25	0.04	0.2
>12 - <50	CC	0.1	0.03	0.12
	SC	0.2	0.03	0.12

# Recommended BACT Levels For Engines (lb/MW-Hr)

---

NOx

0.5

VOC


0.5

CO

1.9

# Recommended BACT Levels for NOx from Electrical Generation (lb/MW-hr)

---



# Recommended BACT Levels for Waste Gas (lb/MW-hr)

---

<u>Technology</u>	<u>NOx</u>	<u>VOC</u>	<u>CO</u>
Turbine	1.25	--	--
Engine	1.9	1.9	7.8

# Implementation of Guidance

---

- **Districts using BACT guidance**
  - **Not using output-based standards**
- **BACT process most expedient tool to achieve central station power plant levels**

# Additional Information

---

[http://www.arb.ca.gov/energy/  
dg/dg.htm](http://www.arb.ca.gov/energy/dg/dg.htm)

[gchin@arb.ca.gov](mailto:gchin@arb.ca.gov)